







Today's Speakers

- Ali Ling
 - H₂S Corrosion
- Mike Harmer
 - Introduction to Pretreatment Programs
- Hamid 'Ed' Abbasi
 - Construction Dewatering Pretreatment

Water Environn Federation





Financial impacts

- Over 70% of wastewater utilities in the USA experience this form of corrosion
- ASCE estimates \$298B needed in next 20 years











Corrosion	Stages	S	
	Stage 1	Stage 2	
Surface pH	12 to 8	8 to 4	
Microbial Activity/ Degree of Corrosion	Limited	Moderate	
			Water Environmen

	Stage 1	Stage 2	Stage 3
Surface pH	12 to 8	8 to 4	4 to 0
Microbial Activity/ Degree of Corrosion	Limited	Moderate	Very Active
		1	pH of 0.1 is

















<section-header><section-header><section-header><text><list-item><list-item><list-item><list-item><image>















What is the Pretreatment Program?

- Pretreatment = Pollutant control requirements for nondomestic sources discharging wastewater to sewer systems that are connected to publicly owned treatment works
- National program
- Implemented through EPA Regions', States' and local program

Water Environn Federation







WSSC's Current vs Proposed Limits For Metals

Pollutant	Current Limit (mg/L)	Proposed Limit (mg/L)
Arsenic	No Limit	0.28
Cadmium	0.17	0.10
Chromium	7.0	7.0
Copper	2.0	2.0
Cyanide	1.0	0.40
Lead	0.4	0.35
Mercury	0.001	0.03
Molybdenum	No Limit	0.35
Nickel	3.4	3.4
Selenium	No Limit	0.4
Silver	1.2	0.50
Zinc	4.2	4.2

Current vs Proposed Limits For Other Pollutants

Pollutant	Current Limit (mg/L)	Proposed Limit (mg/L)
TTO	2.13	No Limit
Tetrachloroethylene	No Limit	0.945
Trichloroethylene	No Limit	0.026
TDS	1,500	5,000
TSS	400	3,000
Total Solids	1,900	8,000
BOD	300	3,000
COD	500	No Limit
Total Phosphorous	No Limit	5
PCBs	No Limit	< 0.001
Fats, oil and grease	100	200
Oil and grease (Nonpolar)	No Limit	250
pH	6.0 - 10.0 s.u.	6.0 - 10.0 s.u.
Temperature	140 F	140 F
Ammonia	No Limit	190









Pretreatment Prohibitions Related To Collection System Protection

Solid or viscous pollutants in amounts which will obstruct flow













Ebola at NIH

- Ebola patients at NIH in 2014
- NIH = Permitted as a SIU





Other Collection System Issues -Capacity and SSOs



<section-header><section-header><section-header><section-header><section-header><section-header>





Prevention and Minimization of SSOs via a Pretreatment Program

Collection System Capacity

- Reviewing Plans
- Communicating with nondomestic users
- Communicating with Collection System staff

Water Environm Federation



Our Next Speaker



Ed Abbasi, PE Senior Industrial Waste Engineer



Water Environ

Construction Dewatering Pretreatment Program

BMP Based General Pretreatment Permit



Construction Dewatering Pretreatment Program

BMP Based General Pretreatment Permit

LEAN Approach

(To create more Value for customers with fewer resources)

Water Environ

Nater Envir

What we do?

Since 1969, the Industrial Waste Program has administered regulations affecting businesses that discharge wastewater into King County's sewage system.

We work cooperatively with more than 650 Industrial users

- We regulate industrial wastewater discharges to the county sewer system by issuing and monitoring wastewater discharge approvals
- We provide technical assistance for industrial users of the county sewer system
- We equitably recover treatment and program costs from industrial users of the sewer system, and
- We protect biosolids and water quality.

Working with many types of industries

- Metal finishing / Electroplating
- Pharmaceutical manufacturers
- Can makers
- Iron manufacturing
- Centralized waste treatment
- Food processors
- Contaminated stormwater
- Construction dewatering



We had a problem -- too much effort for too little value

- During construction, workers pump groundwater, process wastewater and contaminated stormwater away from the site.
- Sometimes they can send this to King County sewers.
- King County was spending too much time managing permits and authorizations for this water.



King County Wastewater Treatment Division

- 34 local sewer agencies (cities & sewer districts)
- > 420 square miles
- > 1.5 million people
- 3 Regional plants (West & South Plants, Brightwater)
- > 2 local plants (Carnation & Vashon Island)
- > 42 Pump Stations
- > 389 miles of conveyance lines
- 38 Combined Sewer Overflows (CSO's) and 4 CSO treatment facilities
- Average 175 million gallons per day (MGD) treated wastewater



Water Environ

King County and the local sewer agency must approve construction dewatering to the sewer

- King County can only accepts construction wastewater when sewer connections is approved by the local sewer authority (LSA).
- LSA sets conditions for:
 - ✓ Discharge point(s)
 - Maximum discharge rate (gpm)
 - Reporting procedures to determine sewer fees.



King County had four types of Construction Dewatering Authorizations

Letter of Authorization

Small uncontaminated flows, monitoring and reporting not required, KCIW does not perform preoperative inspection

Minor Authorization

Small uncontaminated flows, monitoring required but reporting not required, results shall be kept on site, KCIW does perform preoperative inspection

Major Authorization

Larger flows with some contamination, monitoring and reporting required, KCIW does perform preoperative inspection

➤ Permit

Larger flows with significant amount of contaminations, monitoring and reporting required, KCIW does perform preoperative inspection and sampling

Water Environn Federation





Streamlining Analysis

Historically

- About 40% of construction projects are from sites that are:
- <1 acre
- Discharging < 25,000 gpd
- <1 year duration
- Relatively clean, no chemical contaminants

- The other 60% of are from sites that are:
- >1 acre Discharge
- Discharging > 25,000 gpd
- 1-5 years duration
- Chemical contaminants
 present

The Goal of the Pretreatment Program as Described by EPA

Protect POTW and the environment from the adverse impacts that may occur when "Hazardous or Toxic Wastes" are discharged into sewer system.

Water Environ



This protection is achieved by:

Regulating nondomestic users of POTWs that discharge to POTW:

✓ Toxic wastes, or

✓ Unusually strong conventional wastes

Water Environm Federation

Streamlining the other 60%

Points to Consider:

> Maximum flow from the site

Could it be significant?

POTW design criteria and what is considered hydraulically Significant at each POTW?

> Water Environ Federation

- Level of contamination present
- Extent of soil disturbance,
- > Many more......

Is this a SIU?

Any NCIU that discharges an average of 25,000 gpd or more of process wastewater to the POTW; contributes a process waste stream that makes up 5% or more of the POTW ADWF, hydraulic or organic capacity of the POTW; or is designated as such by the POTW on the basis that the IU has a reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement [in accordance with 40 CFR 403.8(f)(6)].

POTW Desig	In Flow	
West Points, Renton Sewage Treatment Plant	Renton Sewage Treatment Plant	Brightwater Treatment Plant
AWWF = 133 mgd ADWF = 110 mgd MMAF=215 mgd Instantaneous maximum = 440 mgd	AWWF = 115 mgd ADWF = 96 mgd MMAF = 144 mgd Instantaneous maximum = 325 mgd	AWWF = 30 mgd ADWF = 25.2 mgd MMAF = 41 mgd Instantaneous maximum = 100 mgd
Significant > 0.25 mgd (<0.23% of ADWF)	Significant > 0.20 mgd (<0.21% of ADWF)	Significant > 0.05 mgd (<0.20% of ADWF)
		Water Environment Federation the water quality people

Ranking Criteria

- ✓ Duration of Discharge
- ✓ Simultaneous Point of Discharge
- ✓ Presence of chemical contaminants,
- ✓ Presence of PCB
- Maximum daily discharge volume gpd
- ✓ Presence of Combined Sewer System

Water Environ

Criteria for Construction Dewatering Discharge Authorization (DA) or Permit						
1 Duration of discharge (month	he)					
Less than 24 months			0			
Longer than 24 months			1 i			
2. Simultaneous Points of Disch	arge					
1 Discharge point	-		0			
2 Discharge Points			1			
More than 2 discharge points			2			
3. Maximum daily discharge vo	lume (gallons per day)					
West Point	South Plant	Brightwater				
Less than 250,000 gpd	Less than 200,000 gpd	Less than 50,000 gpd	0			
More than 250,000 gpd	More than 200,000 gpd	More than 50,000 gpd	1			
4. Combined Sewer						
No			0			
Yes (West Point only)			1			
5. Wastewater Quality/Pretreat	ment system		_			
No known contamination – gravity solids separation only						
Presence of low level soil/groundwater contamination or process wastewater						
Presence of soil/groundwater contamination and/or process wastewater that will require the installation of additional treatment units - these approvals typically do not require review by the KCIW Engineer						
Presence of soil/groundwater con will require installation of more of the proposed treatment system and	tamination such as PCB and orga complex treatment systems 1 and d/or development of specific disc	nics contaminants and/or waste streams that consultation with KCIW Engineer to review harge limits	3			
Total Points:						
Discharge approval type						
Discharge Authorization	□ Less than 5 pc	ints				
Waste Discharge Permit		r than 5 points				

Prede	efineo	d Sampl	ing Fr	equenc	y Crite	ria for N	letals	
	Daily	Instantaneous	West Point /South Plant			Brightwater		
Parameter	Average (mg / L)	Maximum (mg / L)	<100,000 gpd	100,000 - 250,000 gpd	>250,000 gpd	< 25,000 gpd	>25,000 <50,000 gpd	>50,000 gpd
Heavy Metals	LL	LL	1/Quarter	1/Month	Case by Case	1/Quarter	1/Month	Case by Case

Predefined Sampling Frequency for Organic Compounds

	Screening	West Point / South Plant			Brightwater		
Organic Compounds Identified as Present	Level Criteria (µg/L)	< 100,000 gpd	100,000- 250,000 gpd	>250,000 gpd	< 25,000 gpd	25,000 - 50,000 gpd	>50,000 gpd
Organic Compounds	KC limits for Organics	1/Quarter	1/Month	Case by Case	1/Quarter	1/Month	Case by Case

