


# Evolution and Applicability of Pressure Pipe Rehabilitation

November 1, 2017  
1:00 - 3:00 pm Eastern

Thanks to our webcast sponsor!



## How to Participate Today



- Audio Modes
  - Listen using Mic & Speakers
  - Or, select "Use Telephone" and dial the conference (please remember long distance phone charges apply).
- Submit your questions using the Questions pane.
- A recording will be available for replay shortly after this webcast.



## Today's Moderator



Jennifer Steffens, P.E.,  
Senior Project Manager,  
Pure Technologies, Inc.



## Today's Speakers



John Schroeder,  
P.E., Vice  
President at CDM  
Smith



John Matthews,  
Ph.D., Director of  
the Trenchless  
Technology  
Center (TTC) at  
Louisiana Tech  
University



Ian Lancaster,  
Senior Director  
of Pressure Pipe,  
Aegion



John Moody,  
Director of Sales-  
USA,  
Primus Line Inc.



## John P. Schroeder, P.E., BCEE

- National Pipeline Assessment and Rehabilitation Specialist
- 25 Years Experience with CDM Smith
- Columbus, Ohio
- B.S University of Cincinnati, Civil/Environmental Engineering



## Pressure Pipe Prioritization and Assessment

- What pipe should we inspect ?
- How should we inspect ?
- When should we inspect ?
- What Data do we need?
- How much will the data cost?
- What do we do with the data?



## Agenda


1. Why are pipeline inspections Important?
2.  $RISK = \text{Consequence of Failure} \times \text{Probability of Failure}$
3. Failure Trends
4. Components of Condition Assessment Programs



## Why is This Important?



# A Wake-Up Call To All Utilities



As documented in this report, restoring existing water systems as they reach the end of their useful lives and expanding them to serve a growing population will cost at least \$1 trillion over the next 25 years, if we are to maintain current levels of water service. Delaying the investment can result in degrading water service, increasing water service disruptions, and increasing expenditures for emergency repairs. Ultimately we will have to face the need to “catch up” with past deferred investments, and the more we delay the harder the job will be when the day of reckoning comes.




## References

# Evaluate Risk of Failure

*Risk = Prob. of Failure(POF) x Consequence of Failure (COF)*

- Many utilities fixate on probability of failure, but neglect the consequences
- Triple Bottom Line  
Consequence criteria are important
  - Financial Cost \$\$\$
  - Public
  - Environment



This asset given an asset risk index of 13. This is a high-risk asset

Risk Matrix



# Risk Allocation Matrix

		Consequence Score		
		< 50	50 - 75	76 - 100
Likelihood Score	76 - 100	Medium	High	High
	50 - 75	Low	Medium	High
	< 50	Low	Low	Medium



# Consequence Pipe Failure/ Triple Bottom Line

## PUBLIC

- Traffic Delays
- Health and Safety
- Customer Loss of Service



## FINANCIAL

- Emergency Personnel
- Constr. Replacement Costs
- Bypass Pumping
- Commercial Losses
- EPA Fines




## ENVIRONMENTAL

- SSOs, CSOs
- Aquatic Life



Environment  
eration  
er quality people

# Asset Management Continual Life Cycle



Water Environment  
Federation  
the water quality people

## Components of Pipeline Condition Assessment Programs

- Review of Existing Information
- Determine Prominent Failure Points
- Desktop Criticality Analysis
- GIS Tools and Asset Management Integration
- Location/Verification of High Points (for wastewater forcemains)
- Field Work (Excavations, Soils, Water)
  - Pipe Assessment Tools
  - Internal Assessment
  - External Assessment




## Information to Review

- As-Builts Drawings
- Maintenance Records
  - Interviews with Maintenance Staff
- Complaint Logs
- History of Breaks, Leaks & Repairs
- Work Order Forms
- Soils Maps
- Topographic Features
- Existing Nearby Metallic Pipelines and CP Systems





# Desktop Analysis Considers Prominent Failure Points for Estimating Prob. of Failure



## How to establish an inspection prioritization framework?

Risk =

Likelihood of Failure x Consequence of Failure

- Physical Attributes
- Condition Attributes
- Environmental Attributes
- Operational Attributes

- Critical Customer
- Pipe Size
- Pipe Location
- Redundancy



## Likelihood of Failure


- Physical data
  - Age
  - Size
  - Material
- Condition data
  - Pipe condition
  - Joint condition
- Environmental Attributes
  - Soil condition
  - Groundwater table location
- Operational/performance data
  - Pressure
  - Maintenance records
  - Breaks and leaks history

Typical Weighting factors	
Attribute Category	Weighting Factor
Physical	0.15
Condition	0.35
Environmental	0.25
Operations & Performance	0.25




## Pressure Pipe Materials in the U.S.

Pipe Types Used For Sewer Force Mains



## Modes of Failure for Ferrous Pipelines

- Failure modes for metallic force mains



Data source: Water Environment Research Foundation - *Guidelines for the Inspection of Force Mains* (2010)




## Consequence of Failure


- Number of customers served by the pipe
- Proximity to hospitals
- Proximity to large users
- Serving business districts
- Road Type – Interstate, State, Local
- Environmental impact
- Potential for adverse publicity
- Redundancy
  - Existing parallel pipe or existing loop



## What are some of the available inspection technologies?



## Leverage GIS and Data Inputs



# Leverage GIS and Data Inputs


City of Toledo - Raw Water Main Condition Assessment  
60-inch PCCP & 78-inch Steel Parallel Raw Water Mains  
Soil Resistivity Data

*Handwritten notes:* 21000 - very coarse, 2000 - 3000 Med. Coarsness

No.	Pipeline Milepost	Location	Latitude	Longitude	SOIL RESISTIVITY (Ohm-cm)					LAYER LAYER RESISTIVITY (Ohm-cm)					
					0-1% Depth	1-5% Depth	5-10% Depth	10-15% Depth	15-20% Depth	0-1% - 0.5%	0.5% - 1%	1% - 2%	2% - 5%	5% - 10%	10% - 20%
1	0.00	City of Toledo - Raw Water Main	41.450000	-83.410000	2,000	2,000	2,000	2,000	2,000	1,000	700	600			
2	0.10	W. of Oak Street Treatment Plant (S-01)	41.450000	-83.410000	4,117	8,891	8,442	3,157	4,117	1,800	2,070	1,400			
3	0.20	171-01	41.450000	-83.410000	3,244	1,000	6,440	8,011	3,244	700	4,700	1,700			
4	0.30	South Avenue at Oak Street and Oak Crossing (S-02)	41.449270	-83.417020	3,308	3,302	7,201	6,439	3,308	10,100	80,000	17,000			
5	0.40	Other Water Main (S-03)	41.450000	-83.410000	4,462	8,806	8,806	1,400	4,462	1,400	1,400	1,400			
6	0.50	Van Hook Street (S-04)	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
7	0.60	Van Hook Street (S-05)	41.450000	-83.410000	4,478	4,478	1,400	1,400	4,478	800	1,400	800			
8	0.70	Van Hook Street (S-06)	41.450000	-83.410000	4,478	4,478	1,400	1,400	4,478	800	1,400	800			
9	0.80	184-01	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
10	0.90	184-02	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
11	1.00	184-03	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
12	1.10	184-04	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
13	1.20	184-05	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
14	1.30	184-06	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
15	1.40	184-07	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
16	1.50	184-08	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
17	1.60	184-09	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
18	1.70	184-10	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
19	1.80	184-11	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
20	1.90	184-12	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
21	2.00	184-13	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
22	2.10	184-14	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
23	2.20	184-15	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
24	2.30	184-16	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
25	2.40	184-17	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
26	2.50	184-18	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
27	2.60	184-19	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
28	2.70	184-20	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
29	2.80	184-21	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
30	2.90	184-22	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
31	3.00	184-23	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
32	3.10	184-24	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
33	3.20	184-25	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
34	3.30	184-26	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
35	3.40	184-27	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
36	3.50	184-28	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
37	3.60	184-29	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
38	3.70	184-30	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
39	3.80	184-31	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
40	3.90	184-32	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
41	4.00	184-33	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
42	4.10	184-34	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
43	4.20	184-35	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
44	4.30	184-36	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
45	4.40	184-37	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
46	4.50	184-38	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
47	4.60	184-39	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
48	4.70	184-40	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
49	4.80	184-41	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			
50	4.90	184-42	41.449107	-83.446027	8,777	8,803	8,433	2,000	8,777	1,700	2,070	1,700			

Soil Resistivity (Ohm-cm)

Historical Breaks



# Pressure Pipe Assessment Matrix

Technology Testing / Data	Size	Pipe Material	PIPE MATERIAL			PIPE STATUS DURING TEST			Type of	
			Ferrous Corrosion	Corrosion PCCP	ACRCP	Plastic (PVC/HDPE/PP)	In-Service No Excavation	In-Service Excavation		Out of Service Excavate, Open
Name	Firms	APPLICABLE SIZE RANGE					TEST CONDITIONS			
<b>Acoustic/Leak Detection Tools</b>										
Acoustic Leak Detection (Inhered)	Pure Sahara	10" and Up							Leak detection, air pockets	Not installed and rebound for air pockets
Acoustics Leak Detection (surface mount)	Echologics RTLeak/Listener	All Sizes							Leak detection only	Install accelerometers on surface not released yet on fence line
Free Swimming Acoustic Leak Detection	PURE SmartBall	8" and up							Leak detection, air pockets	Not installed and retrieved for borings and removed at man for air pockets
Acoustically Sensitive Fiber Optic	PURE Soundprint AFO	All Sizes							Now - software only for PCCP wire breaks	Future - leak detection, air pockets
	Echologics LeakMonitor	All Sizes							Leak detection	Expected to be effective
<b>Wall Thickness/Condition Tools</b>										
Acoustic Wall Thickness	Echologics	All Sizes			(AC)				Need to porthole for	Remaining wall thickness in DI, CI and ST
	Pure Sahara with PWA	10" and up							Need to porthole for	Average Remaining wall thickness
Broadband Electromagnetic (Internal Pig)	Rock Solid Group allied with several testing firms in US	All Sizes								Remaining wall thickness in CI and DI and ST
Broadband Electromagnetic (External/HSR)										Pipe exterior must be exposed
Magnetic Flux Leakage (External scanner)	AESL	All Sizes								Wall Thickness testing/profiling
Remote Field Eddy Current/MFL	PICA	4" to 24" (to 36" in Urban)								Internal test for metal wall loss, corrosion in DI, CI and ST
Ultrasonic (External)	NDT Coop, MacTec, others	All Sizes			(AC?)					External test for wall thickness
Ultrasonic (Internal)	NDT Coop, Rosen, others	All Sizes								Internal test for wall thickness
Magnetic Tomography	Trankor-K	All Sizes								External test of wall thickness and active corrosion
										Used from the surface
<b>Prestressing Wire Condition Assessment Tools</b>										
Remote Field Eddy Current / Transformer Co	Pure Technologies	Varies by tool								Internal test for wire breaks in PCCP
										Can not insert from 24 to 36 and opened
<b>Other/Ancillary CA Program Components</b>										
Closed Interval Potential Survey	PPT	All Sizes								External test of pipe coating failure (soil corrosion)
										Requires pipe to be electrical
Soil & GW Corrosion Testing	Many Firms/Local Labs	All Sizes								Take soil & groundwater samples for lab analysis
										Indicator only of soil corrosion; secondary use depends on depth
Pipe Coupons or Sampling	Many Firms/Local Labs	All Sizes								Take samples from pipe to compare strength; flexural strength; the universal indicator for AC

## Questions?

Contact Information

John Schroeder

[schroederjp@cdmsmith.com](mailto:schroederjp@cdmsmith.com)



## John C. Matthews, Ph.D.

- Director of the Trenchless Technology Center (TTC) at Louisiana Tech University
- 14 Years Experience in Pipeline Condition Assessment & Rehabilitation
- B.S in Construction Engr. Technology, 2004 (LA Tech)
- M.S. in Civil Engr., 2006 (LA Tech)
- Ph.D. in Civil Engr., 2010 (LA Tech)



## Overview

- Background on Water Main Rehab
- Available Rehabilitation Methods
  - Applicability
  - Advantages
  - Limitations
- Factors for Selecting Methods



## Background

- Many pipelines are reaching the end of their useful lives
- Failure can cause catastrophic damage and emergency repairs are extremely expensive
- Utilities have limited budgets for asset replacements so one must use asset management principals
- A key part of pipeline asset management is rehabilitation to extend the useful life of an asset (see AWWA M36)



## Background

To help utilities gain access to information on pipeline rehabilitation, the EPA published several reports under its Aging Water Infrastructure (AWI) Program

Key reports include:

- A State-of-Technology (SOT) report on Water Main Rehab
- Multiple demonstration projects of innovative rehab technologies
- Multiple reports on innovative condition assessment technology, a key step in the asset management process





## Applicable Rehabilitation Methods

- Pipe bursting & eating involve breaking a host pipe in place, while pulling in a new pipe



## Applicable Rehabilitation Methods

### Sliplining Advantages

- Only trenchless tool capable of upsizing pipe diameter
- Can typically withstand all loads (Class IV)

### Sliplining Limitations

- Services require pits for external reinstatements and many bend conditions
- Surface heave possible under some soil circumstances
- Site must be large enough to layout repair pipe for fusing



## Applicable Rehabilitation Methods

- Sliplining with either close-fit liners or grouted in place pipes or liners



## Applicable Rehabilitation Methods

### Sliplining Advantages

- Can line long straight segments at one time (>1,000 ft)
- Can typically withstand all loads (Class IV)

### Sliplining Limitations

- Services require pits for external reinstatements
- Largest reduction in diameter typically
- Cannot line through most bend conditions (pits required)
- Cleaning requirements for tight fit liners



## Applicable Rehabilitation Methods

- Cured-in-place pipe (CIPP) liners with reinforcing for pressure systems



## Applicable Rehabilitation Methods

### CIPP Advantages

- Can typically withstand all loads (Class IV)
- Robotic reinstatement of service connections
- Can line through various bend conditions up to 45°
- Hydraulic capacity can potentially increase

### CIPP Limitations

- Limited to ~800 ft lining shots
- Excavation required for large bends & damaged services
- Cleaning requirements for tight fit liners



## Applicable Rehabilitation Methods

- Carbon fiber reinforced polymer (CFRP) wraps



## Applicable Rehabilitation Methods

### CFRP Advantages

- Can typically withstand all loads (Class IV)
- Reinstatement of service connections not required
- Can line through any bend conditions
- Hydraulic capacity can potentially increase

### CFRP Limitations

- Only applicable to person-entry sized pipes
- Spot repair mostly, though continual lining is possible
- Cleaning requirements for bonded liners



## Applicable Rehabilitation Methods

- Joint and spot repair systems and seals for leaks



## Applicable Rehabilitation Methods

### Joint Seal Advantages

- Sleeves mechanically lock into place and cannot unlock
- Seals leaking joints and pinholes
- Reinstatement of service connections not required

### Joint Seal Limitations

- Only applicable to person-entry sized pipes
- Non-structural solution limited to point locations
- Cannot seal around bends



## Applicable Rehabilitation Methods

- Spray-on coatings and liners (epoxy, polyurethane, polyurea, cement mortar)



## Applicable Rehabilitation Methods

### Spray-on Lining Advantages

- Reinstatement of services not typically required
- Spans small corrosion holes and joint gaps
- Cures quickly and maintains or improves flow capacity

### Spray-on Lining Limitations

- Cleaning requirements for bonded liners
- Ridging and shadowing common in robotic installations
- Structural claims are unproven for many products



## Factors for Selecting Methods

- Structural Requirements
- Service and Branch Connection Reinstatements
- Flow Capacity Needs
- Pipe Accessibility
- Contractor Availability/Timing
- Diameter, Length, Bend Requirements



## FOR MORE INFORMATION

[WEF & NASSCO Pressure Pipe Committee \(Update\)](#)

EPA Drinking Water & Wastewater Systems Research

- [www.epa.gov/water-research/drinking-water-and-wastewater-systems-research](http://www.epa.gov/water-research/drinking-water-and-wastewater-systems-research)

Trenchless Technology Center (TTC)

- [www.ttc.latech.edu](http://www.ttc.latech.edu)

North American Society for Trenchless Technology (NASTT)

- [www.nastt.org](http://www.nastt.org)



## Questions?

### Contact:

Dr. John C. Matthews

Director of Trenchless Technology Center  
(TTC)

Louisiana Tech University



## Ian A. Lancaster

- Senior Director of Pressure Pipe
  - Aegion is a worldwide engineering, manufacturing and construction corporation
- 20+ years of underground utility experience





# Structural Rehabilitation of Pressurized Pipelines

Ian A. Lancaster  
Sr. Director, Aegion



## Agenda


- Benefits of structural pressurized pipeline rehabilitation
  - Ideal project characteristics
- Cost considerations
- Design parameters
- Proven products/processes
  - Cured-in-place pipe (CIPP)
  - Fiber reinforced polymer (FRP)
  - Modified HDPE slip lining
- Project Steps
- Example Projects




# Benefits of Pressure Pipe Rehabilitation

- Rapid installation
- Minimal excavation
- Maintenance of traffic
- Improved flow characteristics
- Structural stability
  - 50-100 year design
- Corrosion resistance
- Cost savings

Independent



Interactive



# Ideal Projects



- Critical locations
  - High-profile areas, railways, etc.
- Major roadways
- Distribution & transmission pipelines
- Busy right-of-way
- Social costs > Direct costs



# Cost Considerations

The diagram features a central green circle labeled "Value". To its left is a purple box labeled "Economic Costs" with a purple arrow pointing towards the center. To its right is a blue box labeled "Social Costs" with a blue arrow pointing towards the center.



- Economic Costs**
  - Planning
  - Engineering
  - Construction
- Social Costs**
  - Traffic
  - Disruption
  - Environmental Concerns

# Design Parameters

The diagram shows a cross-section of a pipe (red circle) buried in soil. A blue arrow points downwards from the soil surface onto the pipe. To the left, a blue horizontal line represents the groundwater level, with a downward-pointing triangle symbol. The vertical distance from the top of the pipe to the groundwater level is labeled "H". The vertical distance from the top of the pipe to the bottom of the pipe is labeled "D".

- ASTM or AWWA
- Internal design:
  - Operating pressure, transients, vacuum
- External design:
  - Soil, groundwater, traffic, and other live loads
- Other factors:
  - Ovality, bends, services
- Unrestrained burst testing
  - Validates safety factors





# Proven Products/Processes

- Cured-in-place pipe (CIPP)



- Fiber reinforced polymer (FRP)




- Modified HDPE slip lining



# Cured-in-place Pipe (CIPP)

- Thermosetting resin impregnated tube with:
  - Glass reinforced felt
  - Woven polyester jacket
- Diameters from 6" - 96"
- Pressures up to 250 psi
- Tight fitting = flow maximization
- Joint less, pipe-within-a-pipe that protects against corrosion, build-up, and leakage





Since 1997, millions of feet of CIPP pressure pipe has been installed successfully worldwide





## CIPP - Areas of Focus

- Pipeline cleaning
  - High-pressure water
  - Pigging
  - Drag scraping
- Service connection reinstatement
  - Adhesive
  - Mechanical
- End terminations
  - Adhesive
  - Mechanical
  - Specialty Adapters
  - FRP



## CIPP - Service Reinstatement

- Adhesive or Mechanical
  - Step 1 - cleaning of protruding service
  - Step 2 - plugging of existing service connection
  - Step 3 - locating and drilling of the existing service (after lining)
  - Step 4 - installation of mechanical connection



## Fiber Reinforced Polymer (FRP)



- Hand applied thermosetting resin saturated fiber:
  - Carbon
  - Glass
- Diameters:
  - Internal - 30" and greater
  - External - any diameter (exposed)
- Pressures exceeding 450 psi
- Small footprint
- Maximizes inside diameter




## FRP Application



## Modified HDPE Slip Lining

- PE 4710 HDPE material
- Tight-fit or Close-fit
- Custom engineered & manufactured
- Tight fitting = flow maximization
- Installed by compression or deformation
- Diameters from 4" - 66"
- Pressures up to 250 psi



## Modified HDPE Slip Lining

Radial compression



- Diameter is temporarily reduced by radial compression
- Timing is important as the liner will begin to grow back once tension is released
- Can be used for structural or non-structural
- Entire liner section is installed in a single and continuous "pull"

Elastic deformation



- Achieves significant cross sectional reduction to facilitate installation
- Wall thickness limitations—maximum of 1"
- Not suitable for structural loading
- "Fuse and fold" method facilitates small worksite footprint
- Only moderate collapse resistance
- Re-rounded after installation



## Typical Project Steps

- Bypass (if necessary)
- Access pits
- Pipeline cleaning
- Inspection
- Structural lining installation
- Pressure testing
- Service reinstatement (if necessary)
- Chlorination (if necessary)
- Restore service



## Example Projects

- Cured-in-place pipe (CIPP)
  - West Palm Beach, FL - Force Main Rehabilitation
  - 2017 Project of the Year
  - 48" diameter, ~6,000'
- Modified HDPE slip lining
  - Tredyffrin Township, PA - Valley Forge Force Main
  - 2017 Project of the Year, Honorable Mention
  - 30" diameter, ~18,000'
- Carbon fiber reinforced polymer (CFRP)
  - City of Baltimore, MD - (SC) 875, Phase III
  - 2015 Project of the Year, Honorable Mention
  - 78" diameter, ~2,000'





## In Summary...

- Less disruption, compared to excavation
- Fully structural materials
- 50-100 year design life
- Proven products/processes (20+ years)
  - Cured-in-place pipe (CIPP)
  - Fiber reinforced polymer (FRP)
  - Modified HDPE slip lining
- Diameters from 4" - 96"
- Pressure ratings exceeding 450 psi



Thank you for your time! Any questions?



## Flexible Kevlar woven / PE coated Liner



Presented by John Moody  
 Director of Sales-USA  
 Primus Line Inc.



## Pros and Cons of flexible Liner


Benefits of Flexible Kevlar P.E. Coated liner	Considerations for installation
No onsite wet out or cure on site. Liner is inflated with air after install.	Pressure test must be done to insure proper installation. Installers must be certified
Very small foot print and minimal disruption to the environment, only requires a winch to pull in material.	Not a tight fit, annular space= reduction of inside diameter
Pipe does not have to be dry or perfectly clean.	CCTV inspection must be completed prior to installation to confirm suitability. Problem for long runs and multiple bends.
Extremely long runs(8,500LF) with multiple bends including 45 degree bends. High pressures are acceptable	Host pipe is only a conduit for the liner all internal pressure and forces are not conveyed to host. Host must be able to bare soil loads.



### Composition of Primus Liner

**External Layer**

- Abrasion-resistant PE sheath
- Protection of the fabric during insertion





**Kevlar®**

- Seamless, woven aramid fibres (single or double-layered)
- Absorption of the tractive forces during insertion
- Accommodates the operating pressure

**Internal Layer**


- Fluid specific
- Based on PE, TPU
- 15 potable water certifications (AS/NZS 4020:2005/NSF61)





### Liner system consists of ...



Flexible high-pressure composite pipe


...and patented end fittings






Raedinger Primus Line low pressure connector



# Rehabilitation of Twin 12" industrial water lines for Paper Mill under a Highway.

Rand-Whitney Containerboard  
Montville CT.



# Project Details

Year of rehabilitation - January /2017

**Technical Details:**

Host Pipe Material:	Ductile iron
Transported Medium:	Industrial water
Host Pipe Diameter:	12 inch
Operating Pressure:	160 psi
Raedlinger Primus Line® System:	12 inch Primus Liner with a nominal design pressure of 363 psi 4 x 12 inch low pressure connectors with double-sided 12 inch flanges
Total Length:	2 x 980 ft
Number of Construction Sections:	2 installation sections with 980 ft
Installation Time:	3 days for the installation of the Primus Liner and connectors



Line inflated

Connectors installed



Conclusion


- Project was finished on schedule
- There were no issues during the installation
- Cleaning did take longer than anticipated
- One day for cleaning and prep
- One day for installation
- One day for fittings installed/pressure test
- State/ town officials all satisfied with results
- Pipe owner is planning more rehabilitation with this system
- Installer said it could have been completed in two days. He was being cautious as it was his first installation of this system.



End pit.  
Small foot print



# Questions?



- Audio Modes
  - Listen using Mic & Speakers
  - Or, select "Use Telephone" and dial the conference (please remember long distance phone charges apply).
- Submit your questions using the Questions pane.
- A recording will be available for replay shortly after this webcast.



# Evolution and Applicability of Pressure Pipe Rehabilitation

November 1, 2017  
1:00 - 3:00 pm Eastern

**Thanks to our webcast sponsor!**

