


# Ozone Applications at Inland Locations for Potable Reuse

Wednesday December 13, 2017  
1:00 – 2:30 p.m. EDT



## How to Participate Today



- **Audio Modes**
  - Listen using Mic & Speakers
  - Or, select “Use Telephone” and dial the conference (please remember long distance phone charges apply).
- **Submit your questions using the Questions pane.**
- **A recording will be available for replay shortly after this web seminar.**



## Today's Moderator



Justin Mattingly  
WE&RF Research Manager



## WE&RF and WRF Integration

- Represents the evolution of water research
  - 1,200 subscribers
  - 2,300 research studies
  - \$700M integrated research portfolio
- Launches January 1, 2018



## WE&RF and WRF Integration

- A more interconnected research agenda
- Access to an expanded collection of water research
- Leverages funding
- Communicates more effectively with government partners
- Strengthens relationships with water partners
- Creates a model for collaboration across the water community



## Today's Speakers



Vijay Sundaram, P.E.  
Regional Practice Leader,  
Water Sustainability  
Stantec



Denise Funk  
Division Director, Research and  
Development at Gwinnett County  
Department of Water Resources



# Ozone-BAC Technology Development and Demonstration in Reno Nevada

Vijay Sundaram, PE<sup>1,2</sup>


<sup>1</sup>Regional Practice Leader, Water Sustainability, Stantec

<sup>2</sup>PhD Candidate, University of Nevada, Reno



## Potable Reuse Drivers

- Water scarcity
- Single-pipe system
- No cross connection concerns
- Allows for “One Water” management strategy
- Maximum utilization of the water resource



<https://www.e-wef.org/Store/ProductDetails.aspx?productId=58436417>




## Why Ozone-based Trains for Inland Locations?

Technology	Preliminary Relative Capital Cost
O3-BAC-LUV	\$ 1.0x
O3-BAC side-stream RO-OD	\$ 1.4x
RO-H2O2-HUV-OD	\$ 1.7x
O3-BAC-LUV side-stream RO-ZLD	\$ 2.5x
<b>RO-H2O2-HUV-ZLD</b>	<b>\$ 3.3x</b>

**Acronyms:**  
 O3: Ozone  
 BAC: Biological activated carbon  
 LUV: Low-energy UV  
 RO: Reverse Osmosis  
 H2O2: Hydrogen Peroxide  
 HUV: High-energy UV  
 OD: Ocean discharge  
 ZLD: Zero liquid discharge

MF-RO-AOP based treatment trains are widely utilized in potable reuse (PR) applications.

Annual Energy Cost Per MGD (Unit Power Cost = \$0.14/kWh)



## Northern Nevada Potable Reuse Initiative

### 2007 – 2010

- Ozone-BAC technology development
- 20-month continuous field testing
- Findings presentation to Nevada Division of Environmental Protection (NDEP)

### 2015 – Present

- WE&RF 15-10 Ozone-BAC technology optimization project underway in South Truckee Meadows Water Reclamation Facility in Reno
- State of Nevada approved IPR regulations (December 2016)
- Advanced Water Treatment Technologies Demonstration Project – Ongoing Regional IPR Feasibility Study




# Ozone-BAC Technology Development & Demonstration

<p><b>2007 - 2010</b></p> <p><b>Reno-Stead WRF Ozone-BAC Pilot Project</b></p> <p>City of Reno/ Stantec/ WE&amp;RF 08-05 team demonstrated Ozone-BAC as an equally effective alternative to RO for CEC and regulated contaminant removal.</p>	<p><b>2015 - 2018</b></p> <p><b>WE&amp;RF 15-10 Ozone-BAC Optimization Project</b></p> <p>Stantec/ American Water/WE&amp;RF/ Washoe County team is investigating DBP formation of Ozone-BAC effluent and BAC EBCT Optimization.</p>	<p><b>2016 - 2020</b></p> <p><b>UNR Project - Demonstration of IPR Treatment Trains</b></p> <p>University of Nevada Reno (UNR) and Regional Team will conduct "Membrane Free" IPR demonstration projects based on Nevada IPR Regulations.</p>
---	---	---



## Ozone-BAC Introduction

- Ozone**
- A strong oxidant
  - Widely utilized in drinking water treatment
  - Generated onsite (Air, O<sub>2</sub>, Liquid Oxygen)
  - Typical contact time: 3 – 20 minutes



- Biological Activated Carbon (BAC)**
- Activated carbon colonized by microbes
  - Empty bed contact time (EBCT) 10 - 30 minutes
  - Backwashed regularly to:
    - Control biomass
    - Remove suspended solids




## Ozone Pros & Cons

- | Pros  |
|---|
| <ul style="list-style-type: none"> <li>• CEC and Refractory Organics Oxidation</li> <li>• Virus Inactivation</li> <li>• DO Replenishment</li> <li>• Taste, Odor, &amp; Color Improvement</li> </ul> |

- | Cons   |
|--|
| <ul style="list-style-type: none"> <li>• Bromate Formation Potential</li> <li>• Biodegradable Organic Byproducts Formation</li> <li>• NDMA Generation Potential</li> <li>• Incomplete Flame Retardant Removal</li> </ul> |




## Reno-Stead WRF Ozone-BAC Pilot Testing



# Reno-Stead Ozone-BAC Pilot Testing


- WWTP Site: Reno-Stead WRF (RSWRF)
  - Average flowrate = 1.5 Mgal/d
  - Mean cell residence time (MCRT) = 17 to 25 days
  - Average bromide = 240 µg/L
  - Average TDS = 350 mg/L
- Ozone-BAC Continuous Operation
  - Pretreatment:
    - Membrane Filtered (MF) Effluent (10 months)
    - Sand Filtered (SF) Effluent (5 months)
  - Flowrate = 10.7 gpm; BAC Empty Bed Contact Time (EBCT) = 30 minutes



Reno-Stead WRF Project WE&RF 15-10 Regional Project



# CEC Ozone Oxidation



Reno-Stead WRF Project WE&RF 15-10 Regional Project





# Ozone Disinfection Performance

## Ozonation of Membrane Filtered Effluent

Sample Location	Fecal Coliform (MPN/100 mL)	Total Coliform (MPN/100 mL)	MS2 (pfu/100 mL)
Secondary Effluent	>2400	>2400	Not Measured
Membrane Effluent	<0.9	<0.9	1.1 X 10 <sup>8</sup>
After Ozonation with 5 mg/L O <sub>3</sub> & 3.5 mg/L H <sub>2</sub> O <sub>2</sub>	<0.9	<0.9	1- 6 X 10 <sup>0</sup>



## Ozonation of Sand Filtered Effluent

Sample Location	Fecal Coliform (MPN/100 mL)	Total Coliform (MPN/100 mL)
Secondary Effluent	>2400	>2400
Sand Filtered Effluent	>2400	>2400
After Ozonation with 5 mg/L O <sub>3</sub> & 3.5 mg/L H <sub>2</sub> O <sub>2</sub>	2 – 5	140 – 280*


\* Of concern in some effluent uses and regulatory jurisdictions.



# Ozonation Byproducts




## NDMA Formation during Ozonation



Reno-Stead WRF Project WE&RF 15-10 Regional Project



## Role of BAC in Ozonation Byproducts Removal



Reno-Stead WRF Project WE&RF 15-10 Regional Project



## MF-Ozone-BAC CEC Removal

Group	Constituents	Units	Secondary Clarifier Effluent	Membrane Filter Effluent	Ozonation Effluent	BAC Effluent	Blank
Hormones	Estradiol	ng/l	5.9	3.4	1.9	1.8	2
	Estrone	ng/l	65	11.9	0.52	0.5	0.5
	Gemfibrozil	ng/l	45.7	35.3	0.2	0.2	< 0.080
Pharmaceuticals	Ibuprofen	ng/l	4.4	6.4	< 0.39	< 0.39	< 0.39
	Naproxen	ng/l	20.5	17.9	< 0.25	< 0.25	< 0.25
	Triclosan	ng/l	54.7	2.2	< 1.2	< 1.2	< 1.2
	Diazepam	ng/l	2.7	2.8	0.18	< 0.14	< 0.14
	Fluoxetine	ng/l	3.2	2.4	2	< 0.080	< 0.080
	Primidone	ng/l	140	129	4.6	< 0.6	< 0.6
	Trimethoprim	ng/l	270	130	< 2.4	< 2.4	< 2.4
	Atorvastatin	ng/l	14.3	5.5	< 0.11	< 0.11	< 0.11
	Azithromycin	ng/l	323	102	< 22	< 22	< 22
	Caffeine	ug/l	25	10.8	< 0.042	< 0.042	< 0.042
	Ciprofloxacin	ng/l	363	247	< 14	< 14	< 14
	Cotinine	ng/l	54.5	20.5	14	2.3	0.49
	Meprobamate	ng/l	385	343	43.5	3	< 1
	Sulfamethoxazole	ng/l	930	833	6.0	< 0.25	< 0.25
	Methodone	ng/l	65.3	33	0.3	0.13	< 0.4
	Atenolol	ng/l	953	890	10.6	< 1	< 1
	Carbamazepine	ng/l	258	247	0.98	0.8	0.8
	Dilantin	ng/l	253	150	3.1	< 1	< 1
	Diclofenac	ng/l	96	109	< 0.5	< 0.5	< 0.5
	Amoxicillin	ng/l	1633	1020	0.74	ND	ND
Phenytoin	ng/l	390	343	3.9	ND	ND	
Salicylic Acid	ng/l	25	32.67	28	20.67	48.67	
Flame Retardants	TCEP	ng/l	620	545	445	< 3.4	< 3.4
	TCPP	ng/l	2100	2400	1400	< 2.7	< 2.7
	TDCPP	ng/l	633	623	627	0.695	3.23
Industrial EDCs	Bisphenol A	ng/l	18	22	< 0.27	< 0.27	2200
	Octylphenol monoethoxylate	ug/l	31	< 25	< 25	< 25	< 25
Organics	DEET	ng/l	115	125	2.56	< 0.60	1.2
	Musk Ketone	ng/l	47	38	< 25	< 25	< 25
	BHA	ng/l	76	42	< 1	< 1	< 1
	Atrazine	ng/l	1.3	1.5	0.5	< 0.25	< 0.25
	Benzophenone	ng/l	203	173	< 50	< 50	< 50
Ozone Byproducts	1,4-Dioxane	ug/l	1.53	1.5	0.3	0.4	< 0.13
	Formaldehyde	ug/l	9.2	9.8	133.3	5.8	2.4
	Acetaldehyde	ug/l	3.5	2.1	31.0	< 1	< 1
	Ethyl Glyoxal	ug/l	3.3	3.1	41.3	3.9	< 1.1
	Methyl Glyoxal	ug/l	3.3	3.4	27.0	3.7	< 0.5
	Propanal	ug/l	< 0.7	< 0.7	3.5	< 0.7	< 0.7
NDMA	ng/l	1	0.9	7.9	< 0.28	0.385	





Reno-Stead WRF Project

WE&RF 15-10

Regional Project



## TOC Removal and UVT Improvement



Reno-Stead WRF Project

WE&RF 15-10

Regional Project



## WE&RF 15-10 Optimization of Ozone-BAC Processes for Potable Reuse Applications



- Zia Bukhari, PhD
- Ruth Marfil-Vega, PhD
- Patrick Jjemba, PhD
- Matt Surmeier



**Reno Regional  
Agency Team**

- Lydia Peri, Washoe County
- Rick Warner, PE, Washoe County



- Vijay Sundaram, PE
- Jeff Curtis, PhD



- Stefani McGregor
- Project Advisory Committee



- David Foster



Reno-Stead WRF  
Project

WE&RF 15-10

Regional Project



## WE&RF 15-10 Project Objectives

- 1. Monitor DBPs and FP in Ozone-BAC and RO effluents**
  - Establish baselines for Total Trihalomethanes (TTHMs), Haloacetic Acids (HAAs), nitrosamines and their precursors in the effluents
  - Determine relationship between TOC level and DBP FP
- 2. Optimize Ozone-BAC in pilot scale**
- 3. Develop a guidance manual for the potable reuse industry on design and operational optimization of Ozone-BAC systems**



Reno-Stead WRF  
Project

WE&RF 15-10

Regional Project



# Full-Scale Monitoring


Facility ID	Sample ID	System Type	Age, years (at start of monitoring)
BAC 1	BAC 1	Ozone-BAC	GAC Media - 9.0
BAC 2	BAC 2	Ozone-BAC	GAC Media - 1.1
BAC 3	BAC 3A	BAC	GAC Media - 2.7
	BAC 3B	BAC	GAC Media - 2.3
	BAC 3C	Ozone-BAC	GAC Media - 2.3
	BAC 3D	Ozone-BAC	GAC Media - 0.0
RO 1	RO 1	(O3+MF) RO	RO Membrane - 2.3
RO 2	RO 2	(MF) RO	RO Membrane - 2.8



Reno-Stead WRF Project WE&RF 15-10 Regional Project




# THM and HAA Formation Potential



Reno-Stead WRF Project WE&RF 15-10 Regional Project



## Effluent NDMA Concentration




Reno-Stead WRF Project

WE&RF 15-10

Regional Project



## Impact of Ozone on Effluent NDMA Precursors



Sample ID	System Type	Ozone:TOC	Average Ozone:TOC	BAC Media Age (Years)
BAC 3B	BAC	-	-	2.3
BAC 3C	Ozone-BAC	0.5 - 0.6	0.5	2.3



Reno-Stead WRF Project

WE&RF 15-10


Regional Project



## South Truckee Meadows WRF Pilot Testing



**xylem**  
Let's Solve Water



**Goal:** Optimize Ozone-BAC for DBP FP mitigation and CEC removal




Reno-Stead WRF Project

WE&RF 15-10

Regional Project



## Impact of Ozone:TOC Ratio on UV Absorbance



UV<sub>254</sub> absorbance is a reliable field verification parameter for ozonation




Reno-Stead WRF Project

WE&RF 15-10

Regional Project



## Impact of Ozone:TOC Ratio on NDMA Formation and Precursor Removal



NDMA FP reduction with ozone appears to be independent of Ozone:TOC ratio



Reno-Stead WRF Project


WE&RF 15-10

Regional Project



## Steady State Operation

- Ozone:TOC Ratio maintained at 0.9 (no peroxide addition)
- Two parallel BAC units: EBCTs maintained at 10 and 20 minutes
- Steady state operation was initiated end of September
- Sampling events span from October 2017 to February 2018



Reno-Stead WRF Project



WE&RF 15-10

Regional Project





# NDMA Generation and Removal



Reno-Stead WRF Project   WE&RF 15-10   Regional Project



## Truckee Meadows Advanced Technology Demonstration Project

**University of Nevada, Reno**

*Vijay Sundaram, Laura Haak, Lydia Peri, and Krishna Pagilla*



**Regional Agency Team**



*Rick Warner and Lydia Peri, Washoe County; Dave Kershaw and Keri Lanza, City of Reno; Andy Hummel, City of Sparks; John Enloe, Truckee Meadows Water Authority; Michael Drinkwater, Truckee Meadows Water Reclamation Facility; Jim Smitherman, Northern Nevada Water Planning Commission*

**Independent Advisory Panel (IAP)**

*Led by NWRI*



Reno-Stead WRF Project   WE&RF 15-10   Regional Project




# Truckee Meadows Advanced Technology Demonstration Project

- Demonstrate the feasibility of IPR in Nevada based on Nevada IPR Regulations
- Two IPR Methodologies:
  - Spreading Basin
  - Injection Well



## Treatment Train Selection Methodology



## “Membrane Free” IPR Treatment Trains Recommended

Spreading Basin Project Train (Category A Effluent + Vadose Zone Treatment)	Injection Well Project Train (Ozone-BAC AWTF Category A+ Effluent)
Secondary Treatment	Secondary Treatment
Granular Media Filtration with Pretreatment	Coagulation-Flocculation-Clarification
UV Disinfection	Granular Media Filtration (CFC GMF)
Residual Disinfectant (if needed)	Ozone-BAC
Spreading	UV Disinfection
Vadose Zone/Soil Aquifer Treatment	Effluent Polishing
Saturated Zone Travel Time	Residual Disinfectant (if needed)
	Injection
	Saturated Zone Travel Time

Both Spreading Basin and Injection Well Project trains achieve Category A+ Effluent Pathogen Log Reduction Requirements



## Present State-of-the-Art

- Ozone-BAC is effective at removing CECs
- Effluent TOC and its characteristics correlate with regulated DBP formation potential
- Ozonation provides significant NDMA precursor removal
- BAC EBCT is an important design parameter
- Ozone-BAC treatment is currently being implemented in various inland locations, concurrent with ongoing optimization research



## Demonstration of Direct Potable Reuse Using Multi-Stage Ozone-Biological Filtration (BAF)

Denise Funk<sup>1</sup>, PE, BCEE

Jennifer Hooper<sup>2</sup>, PE

Kati Bell<sup>3</sup>, PhD, PE, BCEE

Eddie Machek<sup>4</sup>

<sup>1</sup>Gwinnett County Water Resources

<sup>2</sup>CDM Smith

<sup>3</sup>Stantec

<sup>4</sup>PhD student, Georgia Tech



## Presentation Overview

- Background on Gwinnett County
- Research Objectives
- Pilot Plants
- Select Results
- Next Steps



**Atlanta Metropolitan Region**

- 6 million people
- 15 counties

**Gwinnett County**

- 900,000 people

## Gwinnett County Water Resources Pipes

<p><b>Water Distribution System</b></p> <p style="background-color: #90EE90; padding: 5px; display: inline-block;">3,700 miles</p>	<p><b>Sewer Collection System</b></p> <p style="background-color: #90EE90; padding: 5px; display: inline-block;">3,000 miles</p>	<p><b>Storm Water System</b></p> <p style="background-color: #90EE90; padding: 5px; display: inline-block;">1,500 miles</p>
--	--	---

## Gwinnett County Water Resources Facilities

### Water Production

Two Facilities  
150 MG per Day  
98 MG per Day



### Water Reclamation

Three Facilities  
60 MG per Day  
22 MG per Day  
16 MG per Day




### Wastewater Pump Stations

220 Pump Stations



## Gwinnett County Drinking Water Facilities



## Gwinnett County Water Reclamation Facilities

Water Environment Federation  
the water quality people™

Water Environment Reuse Foundation  
**WERF**

## F. Wayne Hill Water Resources Center

**60 MGD Capacity**

- Phase 1 completed in 2000
- Phase 2 completed in 2006

One of World's Largest Membrane and Ozone Facility

Produces Highest Quality Reuse Water Return to Lake Lanier


Provides Wastewater Treatment for over 50% of Gwinnett County's Residents

Water Environment Federation  
the water quality people™

Water Environment Reuse Foundation  
**WERF**



## F. Wayne Hill Water Resources Center




## Gwinnett County Water Returns and Withdrawals from Lake Lanier





## Gwinnett County Indirect Potable Reuse Treatment Trains




## Why Study Direct Potable Reuse?


- Diversify water supply and resiliency
- Compare DPR to current IPR practice
- Advance the science of Ozone-Biofiltration as an alternative to Reverse Osmosis (RO) based treatment




## Pilot Plant Configuration



## Pilot Plant Treatment Train



## Pilot Plant Facilities



## Pilot Plant Coagulation/Flocculation



## Pilot Plant Controls, Chemicals and Instruments



## Pilot Operational Phases

Phase	Duration	Objectives/Conditions
Baseline	1-2 months	<ul style="list-style-type: none"> <li>Characterize with 100% Lake Lanier influent</li> <li>Compare performance with full scale operations</li> <li>Acclimate biofilters</li> </ul>
DPR Testing of Blending Ratios	5-6 months	<ul style="list-style-type: none"> <li>Test blending ratios</li> <li>15, 25, 50, and 100% F. Wayne Hill effluent</li> </ul>
Robustness	1-2 months	<ul style="list-style-type: none"> <li>Autumn lake water quality challenges</li> <li>Characterize performance over process challenges (e.g. loading rate fluctuation, extended filter run time)</li> </ul>




## Pilot Analytical Matrix

Parameter	Baseline						
	Influent	Ozone Effluent	Coag/Flocc Effluent	Biofilter Effluent	Biofilter Media	Finished Water	Backwash Water
Biological Indicators	●		●	●	●	●	
Organic Characteristics	●	●	●	●			
Trace Chemical Constituents	●						
DBPs/DBP-FP	●	●		●		●	
General Water Quality	●	●	●	●		●	●
Inorganic Chemicals						●	
Operational Parameters	●	●	●	●	●	●	●



## Quarterly Benchmark Sampling Analytical Matrix

Parameter	Location ID									
	1	2	3	4	5	6	7	8	9	10
Biological Indicators	●		●	●		●	●	●	●	●
Organic Characteristics	●				●	●	●	●	●	
Trace Chemical Constituents	●				●	●	●	●	●	
DBPs/DBP-FP	●		●	●	●	●	●	●	●	
General Water Quality	●	●	●	●	●	●	●	●	●	
Inorganic Chemicals	●	●	●	●			●	●	●	
Operational Parameters	●	●	●	●	●	●	●	●	●	●



## Sampling Events

6 laboratories  
+  
70 analytical  
methods  
+  
290 analytes  
=  
Lots of sample  
bottles



## Results – Drinking Water Standards


- 15% Blend – met all primary and secondary standards evaluated
- 25% Blend – exceptions
  - Cyanide (one sample 0.29 mg/L)
  - NDMA (one sample 14 ng/L above CA/MA action level)
- 50% Blend – exceptions
  - Nitrate
  - Bromate (one sample 13 µg/L)
  - Di (2-ethylhexyl) phthalate (one sample 8 µg/L)
  - Color (during robustness only)
  - Manganese (one sample 0.06 mg/L)
  - NDMA (one sample 11 ng/L above CA/MA action level)

## Results - Continued

- 100% FWH – exceptions
  - Nitrate
  - Bromate (one sample 11 µg/L)
  - Cyanide (one sample 0.27 mg/L)
  
- ALL BLENDS
  - HAA5 (< 22 µg/L)
  - TTHMs (< 13 µg/L)
  - Biological parameters all below detection limits (total coliform, fecal coliform, coliphage (somatic and male-specific/F+-specific coliphage, MS2), *enterococcus*, *Legionella*, *Cryptosporidium*, and *Giardia*)




## DPR Pilot Nitrate Results





## DPR Pilot Bromate Results




Bromide - Lake Lanier (average of 54±21 µg/L) and FWH effluent (average of 55±39 µg/L)

FWH Effluent Bromate ranged between 2.6 µg/L and 17 µg/L




## TOC Removal through the FWH Treatment Process







### TOC Removal through the DPR Pilot



### Comparing Full Scale Plant IPR to DPR Pilot Percent TOC Removal






### Comparing Full Scale Plant IPR to DPR Pilot Net TOC Removal




### Operational Benefits of DPR

- Reduced ozone demand/decay
- Mitigation of lake source water quality excursions
- Lower filter headloss accumulation rates








### Lake Temperature Profiles




### Lake Temperature Profiles








### Lake Temperature Profiles




### Comparing Raw Water Temperature during Seasonal Water Quality Challenge





### Comparing Headloss Accumulation Rates – IPR vs DPR



### Next Steps for Gwinnett County

- WERF Project 15-11
  - Draft Report submitted Nov 7, 2017
  - Final Report mid-2018
- Ongoing research projects to optimize service in all areas
- Water Innovation Center





# Acknowledgements


- Project Team
  - Denise Funk, PE, BCEE (PI)
  - Dr. Kati Bell, PE, BCEE (co-PI)
  - Jen Hooper, PE (co-PI)
  - Dr. Ben Stanford
  - Dr. Ching-Hua Huang
  - Eddie Machek
  - Georgia Tech co-ops and interns
  - Morayo Noibi
- Project Advisory Committee
  - Brian Bernados
  - Kelly Comstock
  - Dr. Dan Gerrity
  - Dr. Chance Lauderdale
  - Alex Mofidi
- Water Environment & Reuse Foundation
  - Justin Mattingly



# Questions?



## Questions for Our Speakers?



- Submit your questions using the Questions Pane.

# Thank You